

LOCATION 1403 JACKSON Rd. CITY CRISTINA  
BETWEEN Hillcrest STREET @ St. Michaels Ln STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <u>8</u>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>50'</u>		<u>50' of 1" BARE</u>	
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>0</u>		<u>10-12</u>	<u>94</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>50'</u>			

ENTERS: 1401 BRANCHED INTO: 1403

TAP SIZE: 1" Ser PRESSURE: 20 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION


PRESSURE TEST: @ 100 psi For 44 Hrs. By EP

MAIN SIZE 1" C.I. \_\_\_\_\_ BARE STEEL ☒ COATED STEEL \_\_\_\_\_ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1930

DEPTH: 1 Ft. 6 In. LOCATION

"A" P/S READING .6 TOTAL ANODES 1\* 1 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>P/145/12</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY