

LOCATION 1403 JACKSON ROAD CITY GASTONIA

BETWEEN ST MICHAELS STREET & HILLCREST STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>173</u>		<u>01/29/98</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>35</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>138</u>			

ENTERS: 1403 BRANCHED INTO: Ø

TAP SIZE: 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION 377' EAST of ST. MICHAELS


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY NLS

MAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1994

DEPTH: 4 FT IN. LOCATION 13' NORTH OF JACKSON ROAD

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY