

LOCATION 1407 JACKSON ROADCITY GASTONIABETWEEN ST. MICHAELSSTREET & Hillcrest Ave,

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>208</u>		<u>01/29/98</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>28</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>180</u>			

ENTERS: 1407BRANCHED INTO: ØTAP SIZE: 3/4PRESSURE 60

PSI

INCHES W C

LOCATION 96' East of ST. MICHAEL'SPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY NSMAIN-SIZE 4

C.I. _____

BARE STEEL _____

COATED STEEL _____

PLASTIC XYEAR INSTALLED 1987DEPTH. 4 FT

IN.

LOCATION


14' NORTH OF JACKSON ROAD

"A" P/S READING _____

TOTAL ANODES 1# _____ 17# _____

L.R. # _____

REMARKS:



Test Station

Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY