

LOCATION 1408 JACKSON ROADCITY GASTONIABETWEEN ST MICHAEL

STREET &

Hillcrest


STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>188</u>		<u>01/29/98</u>	
MAIN TO PROP. LINE	<u>11</u>	<u>11</u>	<u>9</u>			
PROP. LINE TO BLDG.	<u>11</u>	<u>11</u>	<u>179</u>			

ENTERS: 1408BRANCHED INTO: ØTAP SIZE: 3/4" PRESSURE 60 PSI _____ INCHES W C LOCATION 240' EAST OF ST. MICHAELPRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY NSMAIN-SIZE 4 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC X YEAR INSTALLED 1997DEPTH: 4 FT IN LOCATION 15' NORTH OF JACKSON ROAD

"A" P/S READING _____ TOTAL ANODES 1# _____ 17# _____ LR # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>SR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY