

LOCATION 1515 JACKSON ROAD

CITY GASTONIA

BETWEEN JACKSON ROAD

STREET &

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	63		01/29/98	
MAIN TO PROP. LINE	11	11	37			
PROP. LINE TO BLDG.	11	11	26			

ENTERS: 1515

BRANCHED INTO: Ø

TAP SIZE: 3/4

PRESSURE 60 PSI

INCHES W C


LOCATION 104' South of JACKSON RD

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY NS

MAIN-SIZE 2 C.I. BARE STEEL COATED STEEL PLASTIC X YEAR INSTALLED 1991

DEPTH: 4 FT. IN LOCATION 17' West of Townsend RD

"A" P/S READING TOTAL ANODES 1# 17# L.R. #

REMARKS: Tied over 12' of existing PLASTIC Service
Installed 51' new 3/4 PLASTIC Service

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	SR	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY