


LOCATION 1301 Jackson Rd CITY GAHANA
 BETWEEN Jackson Rd, STREET & 12th Ave, STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>40'</u>	<u>10-11-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>35'</u>			

ENTERS 1301 BRANCHED INTO D
 TAP SIZE 1/2 PRESSURE 100 PSI INCHES W C LOCATION 80' S of C of Jackson Rd

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL
 MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1995
 DEPTH 3 FT 6 IN LOCATION 12' W of C of 12th Ave.

A P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR # 0851433
 REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	S	
P/S Pipeline Lead White Existing Main	E	

Riser Plastic