

LOCATION 2262 Jacob Rd. CITY GASTONIA

BETWEEN Shaw Ave STREET & JASON DR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	112'	2-19-96		
MAIN TO PROP. LINE	3/4"	P	45'			
PROP. LINE TO BLDG.	3/4"	P	67'			

ENTERS: 2262 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 212' w. of center of Shaw Ave


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By S. Huff

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1972

DEPTH: 3 Ft. 0 In. LOCATION 25' S of center of Jacob Rd.

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 L.R. # 33152

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY