

LOCATION 2616 Jacobs Rd. CITY GASTONIA

BETWEEN Shaw Dr. STREET & JASIN Dr. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>128'</u>	<u>2-20-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>45'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>83'</u>			

ENTERS: 2616 BRANCHED INTO

TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 143' E. of center of

JASIN Dr.


PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY S. HUFF 8/2/94

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED

DEPTH. 3 FT 0 IN LOCATION 20' S. of center of Jacobs Rd.

"A" P/S READING .5 TOTAL ANODES 1# 17 # 1 L.R. # 89796

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY