

LOCATION 300 JAKE Long Rd. CITY GASTONIA  
 BETWEEN Camp Rotary Rd. STREET & ROSE BRIAN STREET

|                   | SIZE       | TYPE           | LENGTH      | INSTALLED      | RETIRED | RENEWED |
|-------------------|------------|----------------|-------------|----------------|---------|---------|
| MAIN TO BLDG.     | <u>3/4</u> | <u>PLASTIC</u> | <u>100'</u> | <u>2-24-99</u> |         |         |
| MAIN TO PROP LINE | <u>3/4</u> | <u>PLASTIC</u> | <u>42'</u>  |                |         |         |
| PROP LINE TO BLDG | <u>3/4</u> | <u>PLASTIC</u> | <u>58'</u>  |                |         |         |

ENTERS 300 BRANCHED INTO 0  
 TAP SIZE: 1/2 PRESSURE 60 PSI INCHES WC LOCATION 646' W of C of Camp Rotary Rd.


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL

MAIN-SIZE 2" C I      BARE STEEL      COATED STEEL      PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3 FT 0 IN LOCATION 13' N of C of JACK Long Rd.

"A" P/S READING PLASTIC N/A TOTAL ANODES 0 17.0 LR 006 4907

REMARKS:  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_  
 \_\_\_\_\_



| Test Station                            |          |                |
|---|----------|----------------|
| Reading & Location                      | Lead     | Volts          |
| P/S Pipeline Lead - Red New Service     | <u>S</u> | <u>Riser</u>   |
| P/S Pipeline Lead - White Existing Main | <u>E</u> | <u>PLASTIC</u> |