

LOCATION 4912 Jamee Dr. CITY EASTONIA
BETWEEN LISA Dr. STREET & Dead End. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>144'</u>	<u>4-26-99</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>PLASTIC</u>	<u>42'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>PLASTIC</u>	<u>102'</u>			

ENTERS 4913 BRANCHED INTO 0
TAP SIZE 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 138' S of C of Lisa Dr.


PRESSURE TEST @ 100 PSI FOR 74 HRS BY RL

MAIN SIZE 2" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1984

DEPTH: 3 FT 0 IN LOCATION 16' E of C of Jamee Dr.

"A" P/S READING PLASTIC TOTAL ANODES 1# 0 17# 0 L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Rise</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>PLASTIC</u>

COPIED