

LOCATION 3029 Jamestown Dr. CITY Gastonia

BETWEEN Robinson Rd. STREET & Raleigh Ct STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>106'</u>	<u>10-9-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>10'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>96'</u>			

ENTERS: 3029 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W C LOCATION 314' S. of center of

Raleigh Ct


PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY S. Guffey

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 3 FT 0 IN LOCATION 20' W. of center of Jamestown Dr.

"A" P/S READING 1.0 TOTAL ANODES 1# 0 17# 0 L.R. # 686817

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY