

LOCATION 425 JASIN DR. CITY COASTONIA

BETWEEN SUGAR SPRING STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED <input checked="" type="checkbox"/>	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>134'</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>10'</u>			<u>2-12-99</u>
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>124'</u>			

ENTERS 425 BRANCHED INTO 0

TAP SIZE 3/4 PRESSURE 60 PSI INCHES W.C. LOCATION

PRESSURE TEST @ 100 PSI FOR 164 HRS BY EP

MAIN SIZE 2" C I BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1972

DEPTH 3 FT 6 IN LOCATION

"A" P/S READING 1.4 TOTAL ANODES 1# 17# LR #

REMARKS.

