

LOCATION 539 JASIN Dr. CITY Coastonia
BETWEEN Gardner Park STREET & - STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>C/W</u>	<u>8'</u>	<u>Relocated</u>	<u>8/25/98</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						

ENTERS. 539 BRANCHED INTO 0
TAP SIZE 3/4 Ser. PRESSURE 60 PSI _____ INCHES W C LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS BY EP
MAIN SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED _____
DEPTH: 2 FT 0 IN LOCATION

"A" P/S READING 1.2 TOTAL ANODES 1# 1 17# _____ L.R. # _____

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>Rise</u>	<u>1.2</u>
	P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY