

LOCATION 1407 Jenkins Rd CITY Easton
BETWEEN Northwest Blvd STREET & Poplar St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>179</u>	<u>10-8-54</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>44</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>135</u>			

ENTERS: 1407 BRANCHED INTO:
TAP SIZE: 3/8 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Waste House


PRESSURE TEST: @ 150 psi For 114 Hrs. By Bornett

MAIN-SIZE 6 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED 1964

DEPTH: 2 Ft. 6 In. LOCATION 14' E of C/H

"A" P/S READING 1.30 TOTAL ANODES 1* _____ 17* _____ L.R. # 444699

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY