

LOCATION 400 Jenny St. CITY Gastonia.
BETWEEN Melvin Dr. STREET & Willimax Ave. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.						
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						


ENTERS: _____ BRANCHED INTO: _____
TAP SIZE: _____ PRESSURE _____ PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ _____ PSI FOR _____ HRS. BY _____
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL ☒ PLASTIC _____ YEAR INSTALLED 1959
DEPTH: 3' FT. 6" IN. LOCATION Melvin Dr.

"A" P/S READING 1.975 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS: Bonded insulated fee on 3/4" C+W 1/2 service line to 2" C+W gas main. C.P.#01872.

Readings: .300 before bond + 1.780 after bond was made.

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	S		
	P/S Pipeline Lead - White Existing Main	E		