

LOCATION 1513 + 1515 Jewett St

CITY Gastonia

BETWEEN CAROLINA

STREET & Westview

STREET

	SIZE	TYPE	1515 LENGTH	1513	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	78'	14'			
MAIN TO PROP. LINE	3/4	P	10'	4'			7-27-96
PROP. LINE TO BLDG.	3/4	P	68'	10'			

ENTERS: 1515

BRANCHED INTO: 1513

TAP SIZE: 1/2

PRESSURE 20 P.S.I. _____ INCHES W.C.

LOCATION

PRESSURE TEST: @ 105 psi For 1/4 Hrs. By EP

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED 1994


DEPTH: 1 Ft. 6 In. LOCATION

"A" P/S READING P

TOTAL ANODES 1# 17#

L.R. #

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Plastic
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY