

LOCATION 526 Johns Ln CITY Crossville
BETWEEN Perry St STREET & Wood St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>74'</u>			
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>30'</u>			<u>3-23-98</u>
PROP. LINE TO BLDG.	<u>3/4</u>	<u>P</u>	<u>44'</u>			

ENTERS: 526 BRANCHED INTO: 0

TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST: @ 100 PSI FOR 14 HRS. BY EP

MAIN-SIZE 4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1998

DEPTH: 3 FT. 6 IN. LOCATION _____

"A" P/S READING P TOTAL ANODES 1# 17 L.R. # _____

REMARKS: _____

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0.195V</u>	
	P/S Pipeline Lead - White Existing Main	<u>E</u>		