

LOCATION

620 John's Lane

CITY

Gastonia

BETWEEN

S. Perry

STREET &amp;

Florida

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	74'		4	13-98
MAIN TO PROP. LINE	"	"	8'			
PROP. LINE TO BLDG.	"	"	66'			

ENTERS:

620

BRANCHED INTO:

624

TAP SIZE:

3/4

PRESSURE

60

PSI

INCHES W.C.

LOCATION

PRESSURE TEST: @

100

PSI

FOR

1/4

HRS.

BY

SE

MAIN SIZE

3/4 Ssp

C.I.

BARE STEEL

COATED STEEL

PLASTIC

✓

YEAR INSTALLED

1-24-1992

DEPTH:

2 FT. D

IN.

LOCATION

"A" P/S READING


Plastic

TOTAL ANODES 1#

17#

L.R. #

REMARKS:



Test Station

Reading &amp; Location

Lead

Volts

P/S Pipeline Lead - Red  
New Service

Riser

Plastic

P/S Pipeline Lead - White  
Existing Main

E

ENG. DEPT. USE ONLY