

LOCATION 1215 Jones St CITY GASTONIA

BETWEEN Home Trail STREET & Jackson St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>68'</u>			<u>1-10-98</u>
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>63'</u>			

ENTERS: 1215 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI          INCHES W.C. LOCATION 352' E. of center of

Home Trail


PRESSURE TEST: @ 100 PSI FOR 44 HRS. BY S. Hufstetler

MAIN-SIZE 2" C.I.          BARE STEEL          COATED STEEL          PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION 13' S. of center of Jones St

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # ✓

REMARKS:

	Test Station			ENG. DEPT. USE ONLY
	Reading & Location	Lead	Volts	
	P/S Pipeline Lead - Red New Service	<b>S</b>		
	P/S Pipeline Lead - White Existing Main	<b>E</b>		