

LOCATION 1931 Jordache Ct CITY Conover
BETWEEN Delta STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>P</u>	<u>157'</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>P</u>	<u>10'</u>	<u>8-10-01</u>		
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>147'</u>			

ENTERS 1931 BRANCHED INTO 0
TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____


PRESSURE TEST @ 100 PSI FOR 114 HRS BY EP

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 2000

DEPTH 3 FT 0 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# — 17# — LR # _____

REMARKS _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>None</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	