

LOCATION 1932 JORDACNE CT. CITY GAST
BETWEEN DELTA STREET & CUL DB SAC STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	2"	PLAS.	219'	6.7.2000		
MAIN TO PROP LINE	"	"	40'			
PROP LINE TO BLDG.	"	"	179'			

ENTERS: 1932 BRANCHED INTO.
TAP SIZE: 2" PRESSURE 60 PSI _____ INCHES WC LOCATION W. of 1932

PRESSURE TEST: @ 100 PSI FOR 1742 BY GL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC / YEAR INSTALLED 2000
DEPTH: 3 FT. IN. LOCATION W. side of Jordacne

"A" P/S READING N/A TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	