

LOCATION 925 Jupiter St. CITY BASTONIA
BETWEEN Crescent Ln. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>165'</u>	<u>10-9-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>60'</u>			


ENTERS: 925 BRANCHED INTO: 0
TAP SIZE: 1/2 PRESSURE 60 PSI _____ INCHES W.C. LOCATION 380' w of C of Crescent Ln.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY BL
MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1995

DEPTH: 3 FT. 0 IN. LOCATION 17' w of C of Jupiter St.

A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 567520

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY