

LOCATION 1309 KAYLOR CT CITY GASTONIA  
BETWEEN FLOYD LN STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>D</u>	<u>46'</u>			
MAIN TO PROP LINE	<u>3/4</u>	<u>D</u>	<u>5'</u>	<u>8-19-59</u>		
PROP LINE TO BLDG	<u>3/4</u>	<u>D</u>	<u>41'</u>			

ENTERS 1309 BRANCHED INTO 0  
TAP SIZE 1/2 PRESSURE 600 PSI INCHES WC LOCATION


PRESSURE TEST 100 PSI FOR 114 HRS BY EF

MAIN SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED 1998

DEPTH 3 FT 6 IN LOCATION

"A" P/S READING D TOTAL ANODES I# T# LR#

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>0.95V</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	