

LOCATION 1317 & 1308 KAYLOR ST CITY Easton  
BETWEEN FLOYD LN STREET & STREET

	SIZE	TYPE	1317 LENGTH	1308	INSTALLED	RETIRED	RENEWED
M. + TO BLDG.	<u>3/4</u>	<u>P</u>	<u>53</u>	<u>93</u>	<u>8-19-99</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>P</u>	<u>5</u>	<u>20</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>P</u>	<u>48</u>	<u>73'</u>			

ENTERS: 1317 BRANCHED INTO 1308  
TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION

PRESSURE TEST. @ 100 PSI FOR 1/4 HRS BY EP

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1998

DEPTH: 3 FT 6 IN LOCATION

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ I.R. # \_\_\_\_\_

REMARKS  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead Red New Service	<u>S</u>	<u>0.7564</u>
P/S Pipeline Lead White Existing Main	<u>E</u>	

