

LOCATION ¹¹⁰³ Sewing Concepts Inc Kendrick Rd CITY Gastonia
BETWEEN Robinswood Rd STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	C&W	172'	^{TIE BUCK} 5/1/96		
MAIN TO PROP. LINE	3/4"		16'			
PROP. LINE TO BLDG.	3/4"		156'			


ENTERS: Sewing Concepts BRANCHED INTO:
TAP SIZE: 3/8" PRESSURE 60 P.S.I. INCHES W.C. LOCATION W Side of Sewing Concepts

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By DT
MAIN-SIZE 6" C.I. BARE STEEL COATED STEEL ☒ PLASTIC YEAR INSTALLED 1996
DEPTH: 3' Ft. 0 In. LOCATION W Side of Kendrick Rd

"A" P/S READING 1.20 TOTAL ANODES 1* 0 17* 0 L.R. #

REMARKS: P.S. Reading taken on MAIN WAS 1.20
P.S. Reading on Ex Riser WAS 1.10

Tied over 156' of EX 3/4" C&W service with
16' of 3/4" C&W Pipe



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>R</u>	<u>1.10</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY