

LOCATION 1132 Kendrick Rd.CITY GASTOWIABETWEEN Barrington Rd.STREET & Robinwood Rd.

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>186'</u>	<u>8-10-95</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>51'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>135'</u>			


ENTERS: 1132BRANCHED INTO: 0TAP SIZE: 3/8

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION 992' W of C of Barrington Rd.PRESSURE TEST: @ 100 psi For 1/4 Hrs. By RLMAIN-SIZE 3" C.I. BARE STEEL COATED STEEL ✓ PLASTIC YEAR INSTALLED 1958DEPTH: 3 Ft. 0 In. LOCATION 14' S of C of Kendrick Rd."A" P/S READING 1.2TOTAL ANODES 1# 17# L.R. # 364 786REMARKS: New 3/4 Plastic Service with Road Bore. (TW) Main in Excellent Condition.

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY