

LOCATION 2317 Kendrick Estates DR CITY Gastonia
BETWEEN Stoney Creek Ct STREET & Deadend STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>96'</u>	<u>9-5-97</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>"</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>"</u>	<u>90'</u>			


ENTERS: 2317 BRANCHED INTO: —
TAP SIZE: 3/4 PRESSURE 60 PSI — INCHES W.C. LOCATION

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY SE
MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1996

DEPTH: 3 FT. 8 IN. LOCATION

"A" P/S READING Plastic TOTAL ANODES 1# — 17# — L.R. # 592256

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY