

LOCATION 2333 Kendrick Estates dr CITY Gastonia

BETWEEN Stoney Creek Ct. STREET & Dead End STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	83'	8-6-98		
MAIN TO PROP. LINE	11	11	8'			
PROP. LINE TO BLDG.	11	11	75'			

ENTERS: 2333 BRANCHED INTO: —

TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C. LOCATION 18' S. of Cot

Kendrick Estates dr


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY JR

MAIN-SIZE 2" C.I. — BARE STEEL — COATED STEEL — PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 7 FT. 0 IN. LOCATION —

"A" P/S READING P TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>DR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY