

LOCATION 3633 Kendrick Est. dr CITY Gastonia
BETWEEN Stoney Creek STREET & Gastonia day Sat Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>84'</u>	<u>2-9-99</u>		
MAIN TO PROP. LINE	<u>1"</u>	<u>1"</u>	<u>9'</u>			
PROP. LINE TO BLDG	<u>1"</u>	<u>1"</u>	<u>25'</u>			

ENTERS: 3633 BRANCHED INTO
TAP SIZE: 1/2 PRESSURE _____ PSI _____ INCHES WC LOCATION 18 W. of COJ


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY JP Stoney Creek

MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 3 FT 0 IN LOCATION _____

"A" P/S READING P TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:

	Test Station		
	Reading & Location	Lead	Volts
	P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
	P/S Pipeline Lead - White Existing Main	<u>E</u>	