

LOCATION

1206 Kenilworth

CITY

Gastonia

BETWEEN

Old west

STREET &amp;

Meadowbrook

STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	P	3'	7-30-94	Tied down	119' of EXT
MAIN TO PROP. LINE					3/4" W 5m to EXT 2"	
PROP. LINE TO BLDG.					PLASTIC MAIN	

ENTERS:

1206

BRANCHED INTO: E

TAP SIZE:

1/2

PRESSURE

60

P.S.I.

INCHES W.C.

LOCATION

PRESSURE TEST: @

100

psi

For

14

Hrs.

By

EF

MAIN-SIZE

2"

C.I.

BARE STEEL

COATED STEEL

PLASTIC

YEAR INSTALLED

1973

DEPTH:

3

Ft.

6

In.

LOCATION

"A" P/S READING

P

TOTAL ANODES 1\*

1


17\*

L.R. #

REMARKS:

Tracer wire tied off at main.

Removed 3/4 Insulated Tee



Test Station

ENG. DEPT. USE ONLY

Reading &amp; Location

Lead

Volts

P/S Pipeline Lead - Red  
New Service

R/S

7.2

P/S Pipeline Lead - White  
Existing Main

E