

LOCATION 1402 & 1410 Kenilworth CITY Bastonia  
 BETWEEN Cloverdale STREET & Belmar STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>3'</u>	<u>7-30-94</u>	<u>Tied over 126' ST</u>	
MAIN TO PROP. LINE					<u>Ext 3/4 C/W to 1402</u>	
PROP. LINE TO BLDG.					<u>to Ext 2' Plastic Man</u>	

ENTERS: 1402 BRANCHED INTO: 1410  
 TAP SIZE: 1/2 PRESSURE 60 P.S.I. \_\_\_\_\_ INCHES W.C. LOCATION \_\_\_\_\_


PRESSURE TEST: @ 100 psi For 14 Hrs. By EP

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ☒ YEAR INSTALLED 1993

DEPTH: 3 Ft. 6 In. LOCATION \_\_\_\_\_

"A" P/S READING P TOTAL ANODES 1\* 1 17\* \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: Tracer wire tied off at main  
Removed Insulated dresser



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u> <u>1402-13</u>	<u>#1402 -</u> <u>#1410 -</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY

1.2  
1.2