

LOCATION 3710 Kennedy Rd. CITY Castonia

BETWEEN EAST Hampton DR STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>67'</u>	<u>4-18-97</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>60'</u>			

ENTERS: 3710 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 600 PSI INCHES W.C. LOCATION 200' S. of center of
EAST Hampton DR


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Huffstut

MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED

DEPTH: 3 FT. 0 IN. LOCATION 21' W. of center of Kennedy Rd.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 241872

REMARKS:

	Test Station		ENG. DEPT. USE ONLY
	Reading & Location	Lead	
	P/S Pipeline Lead - Red New Service	S	
	P/S Pipeline Lead - White Existing Main	E	