

LOCATION 3721 Kennedy St. CITY Gastonia
BETWEEN Laver Ct. STREET & STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>5/8"</u>	<u>P</u>	<u>134'</u>	<u>8-16-02</u>		
MAIN TO PROP LINE	<u>5/8"</u>	<u>P</u>	<u>44'</u>			
PROP LINE TO BLDG	<u>5/8"</u>	<u>P</u>	<u>90'</u>			

ENTERS Some BRANCHED INTO

TAP SIZE 1/2" PRESSURE 60 PSI INCHES W.C. LOCATION 19' North of

Kennedy St. & 116' East of Laver Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY B. Ballard

MAIN-SIZE 2" C I BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED

DEPTH 3 FT 6 IN LOCATION 19' North of Kennedy St.

"A" P/S READING Plastic TOTAL ANODES 1# 0 17# 0 LR #

REMARKS

New 5/8" plastic serv.

