

LOCATION: 3740 Kennedy Rd. CITY: Castonig
BETWEEN LAVER CT STREET & Newcombe Ln. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	P	67'	5-22-98		
MAIN TO PROP. LINE	3/4"	P	5'			
PROP. LINE TO BLDG.	3/4"	P	62'			


ENTERS: 3740 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 PSI INCHES W.C. LOCATION 92' N. of center of LAVER CT.

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY S. Hufstetler
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ☒ YEAR INSTALLED

DEPTH: 3 FT. 0 IN. LOCATION 19' W. of center of Kennedy Rd.

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 369745

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY