

LOCATION 3757 Kennedy Rd. CITY BASTONIA  
BETWEEN Laver Ctr STREET & End of Culdesack STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>136'</u>	<u>12-16-96</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>46'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>90'</u>			

ENTERS: 3757 BRANCHED INTO: 0  
TAP SIZE: 1/2 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION 305' S of C of Laver Ctr

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY AL  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1994  
DEPTH: 3 FT. 6 IN. LOCATION 20' W of C of Kennedy Rd.

"A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 L.R. # 714706

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY