

LOCATION 3770 Kennedy Rd CITY Gastonia  
BETWEEN LAVER CT STREET & Lead out STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>P</u>	<u>65'</u>	<u>10-21-98</u>		
MAIN TO PROP. LINE	<u>1'</u>	<u>1'</u>	<u>7'</u>			
PROP. LINE TO BLDG.	<u>1'</u>	<u>1'</u>	<u>58'</u>			


ENTERS: 3770 BRANCHED INTO:  
TAP SIZE: 1/2 PRESSURE \_\_\_\_\_ PSI \_\_\_\_\_ INCHES W.C. LOCATION 21' w. of cop  
Kennedy

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY APP  
MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC ✓ YEAR INSTALLED 1997

DEPTH: 3 FT. 0 IN. LOCATION \_\_\_\_\_

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS: \_\_\_\_\_



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>OR</u>	<u>P</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY