


LOCATION 1244 Kennett Ave CITY Gastonia
 BETWEEN Elder Ct STREET & End of Caudesack STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>95'</u>	<u>11-6-02</u>	<u>75' OF Existing</u>	<u>3/4</u>
MAIN TO PROP LINE	<u>3/4</u>	<u>Plastic</u>	<u>15</u>	<u>orig inst</u>	<u>Plastic OFF OF</u>	
PROP LINE TO BLDG	<u>3/4</u>	<u>Plastic</u>	<u>80</u>	<u>11-13-2000</u>	<u>Adjacent Lot</u>	

 ENTERS 1244 BRANCHED INTO 0
 TAP SIZE 3/4 PRESSURE 60 PSI _____ INCHES W C LOCATION 30' W of C of Elder Ct.

PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY RL
 MAIN SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1998
 DEPTH 3 FT 0 IN LOCATION 36' South of C of Kennett Ave.
 "A" P/S READING Plastic N/A TOTAL ANODES 1# 0 17# 0 LR # _____

REMARKS



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	Riser
P/S Pipeline Lead - White Existing Main	E	Plastic