

LOCATION 1267 Kennell Ave CITY Gastonia

BETWEEN Elder Ct STREET & Palmer St STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>80'</u>	<u>4-24-00</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>77'</u>			

ENTERS: 1267 BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 PSI INCHES W.C. LOCATION 113' W. of center of Elder Ct


PRESSURE TEST: @ 100 PSI FOR 44 HRS BY S.H.

MAIN-SIZE 2" C.I.  BARE STEEL  COATED STEEL  PLASTIC ✓ YEAR INSTALLED 1989

DEPTH: 3 FT. 0 IN. LOCATION 19' S. of center of Kennell Ave

"A" P/S READING P TOTAL ANODES 1# 0 17# 0 L.R. # 313514

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	