

LOCATION 1273 KENNETT AVE CITY GASTONIA
BETWEEN ELDER CT STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4</u>	<u>plastic</u>	<u>59'</u>	<u>9-1-00</u>		
MAIN TO PROP LINE	<u>3/4</u>	<u>plastic</u>	<u>7'</u>			
PROP LINE TO BLDG	<u>3/4</u>	<u>plastic</u>	<u>52'</u>			

ENTERS 1273 BRANCHED INTO 0
TAP SIZE 1/2 PRESSURE 60 PSI _____ INCHES WC LOCATION 25' W of C of
ELDER CT

PRESSURE TEST @ 100 PSI FOR 44 HRS BY R.R.

MAIN-SIZE 2" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1999

DEPTH 3' FT 0 IN LOCATION 20' S of C of KENNETT AVE

"A" P/S READING plastic TOTAL ANODES 1# 0 17# 0 LR # 0812286

REMARKS

Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>River</u>

