

LOCATION 1291 Kennett Ave. CITY Gastonia
BETWEEN Heritage Commons STREET & Elder Ct. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG	<u>3/4"</u>	<u>P</u>	<u>78'</u>	<u>2-19-01</u>		
MAIN TO PROP LINE	<u>3/4"</u>	<u>P</u>	<u>4'</u>	<u>"</u>		
PROP LINE TO BLDG	<u>3/4"</u>	<u>P</u>	<u>74'</u>	<u>"</u>		

ENTERS 1291 Kennett Ave. BRANCHED INTO A
TAP SIZE 1/2" PRESSURE 60 PSI _____ INCHES W/C LOCATION 109' west


PRESSURE TEST @ 100 PSI FOR 1/4 HRS BY D.E.
center of Heritage Commons

MAIN-SIZE 2" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1999

DEPTH 3' FT 0" IN LOCATION 20' south of center of Kennett Ave.

"A" P/S READING N/A TOTAL ANODES 1# 0 17# 0 LR # 00111198

REMARKS new 3/4" plastic service



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>riser</u>