

LOCATION 5019 Kentwood DR.CITY CASTONIABETWEEN KENDRICK Rd

STREET &

STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>Plastic</u>	<u>6'</u>	<u>9-9-94</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>"</u>	<u>6'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>"</u>	<u>6'</u>			

ENTERS: 5019 Kentwood DR.

BRANCHED INTO:

TAP SIZE: 3/4" PRESSURE 60 P.S.I. _____ INCHES W.C. LOCATION West Side of 5019PRESSURE TEST: @ 100 psi For 1/4 Hrs. By zmf~~MAIN~~ ^{SERVICE} SIZE 3/4" C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ☒ YEAR INSTALLED 1992DEPTH: 2 Ft. 6 In. LOCATION _____"A" P/S READING _____ TOTAL ANODES 1* 17* _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY