

LOCATION 1473 KIAWAH CT CITY CASTANIA

BETWEEN WHITE HALL PL. STREET & DEAD END. STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>45'</u>	<u>1-3-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>0</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>45'</u>			

ENTERS: 1473 BRANCHED INTO:

TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 26' N. of center of

KIAWAH CT


PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. HUFFBARTH

~~Service~~ MAIN SIZE 3/4" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1994

DEPTH: 2 Ft. 0 In. LOCATION 208' E. of center of White Hall Pl.

"A" P/S READING 7 TOTAL ANODES 1* 0 17* 0 L.R. # 592613

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY