

LOCATION 649 Kilbourne Dr CITY GASTONIA
BETWEEN Belfast Dr STREET & DEAD END STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>C&W</u>	<u>12'</u>		<u>RELOCATED</u>	
MAIN TO PROP LINE	<u>3/4"</u>	<u>"</u>	<u>12'</u>		<u>9-15-00</u>	
PROP LINE TO BLDG	<u>3/4"</u>	<u>"</u>	<u>12'</u>			

ENTERS: SAME BRANCHED INTO: 0
TAP SIZE: 3/8" PRESSURE 60 PSI _____ INCHES W.C. LOCATION 103' West from
& of Kilbourne


PRESSURE TEST. @ 100 PSI FOR 1/4" HRS BY MD

~~MAIN SIZE~~ 3/4" C I _____ BARE STEEL _____ COATED STEEL _____ PLASTIC _____ YEAR INSTALLED p.33

ser DEPTH: 1 FT 6 IN LOCATION WEST SIDE of Kilbourne

"A" P/S READING 1.2 TOTAL ANODES 1# _____ 17# _____ L.R. # _____

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	