

LOCATION 1632-A Kimberly Dr. CITY Houston
BETWEEN Old West Lane STREET & Belmar STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>1</u> <u>3/4</u>	<u>Bare Steel</u> <u>Plastic</u>	<u>83</u> <u>82</u>	<u>7-30-94</u>	<u>7-30-94</u>	
MAIN TO PROP. LINE	<u>3/4</u>		<u>6</u>			
PROP. LINE TO BLDG.	<u>3/4</u>		<u>76</u>			

ENTERS: 1632-A BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Inside House


PRESSURE TEST: @ 100 psi For 1 1/4 Hrs. By Bennett
MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993
DEPTH: 2 Ft. 6 In. LOCATION 19' N. of 1st St.

"A" P/S READING _____ TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS:

Retired Service Piped
With Air And
Capped With N

Bare Main Replacement
Program ✓



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY