

LOCATION 1635 Kimberly Dr CITY Sacramento
BETWEEN Old West Lane STREET & Belmar STREET

	SIZE	TYPE	P	LENGTH S	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4	Plastic	3	78	Tied over 7-23-94		
MAIN TO PROP. LINE	3/4	"	3	37			
PROP. LINE TO BLDG.	3/4	"	0	41			

ENTERS: 1635 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE _____ P.S.I. _____ INCHES W.C. LOCATION Side House

PRESSURE TEST: @ 100 psi For 14 Hrs. By Bonnett


MAIN-SIZE 2 C.I. _____ BARE STEEL _____ COATED STEEL _____ PLASTIC ✓ YEAR INSTALLED 1993

DEPTH: 2 Ft. 6 In. LOCATION 17' W of Old West Lane

"A" P/S READING 1010 TOTAL ANODES 1* _____ 17* _____ L.R. # _____

REMARKS: This was bonded

~~Rare~~ Main Replacement
Program



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY