

LOCATION 209 & 207 N. King CITY GAST.  
BETWEEN AIRLINE STREET & RANKIN STREET

	SIZE	TYPE	209 LENGTH	207	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	3/4"	D	63'	15"		6-19	-96
MAIN TO PROP. LINE	"	"	5'	0			
PROP. LINE TO BLDG.	"	"	58'	15'			

ENTERS: 209 BRANCHED INTO: 207

TAP SIZE: 3/4" PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION S. of 209  
N. of 207


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY GK

MAIN-SIZE 2 C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL \_\_\_\_\_ PLASTIC / YEAR INSTALLED 96

DEPTH: 3 FT. IN. LOCATION W. side of N. King

"A" P/S READING P TOTAL ANODES 1# \_\_\_\_\_ 17# \_\_\_\_\_ L.R. # \_\_\_\_\_

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	S	P
P/S Pipeline Lead - White Existing Main	E	

ENG. DEPT. USE ONLY