

LOCATION 215 S. King ST CITY Castroville
BETWEEN Franklin Blvd STREET & Second Ave. STREET


	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>53'</u>	<u>9-30-95</u>		
MAIN TO PROP. LINE	<u>3/4"</u>	<u>P</u>	<u>3'</u>			
PROP. LINE TO BLDG.	<u>3/4"</u>	<u>P</u>	<u>50'</u>			

ENTERS: 215 BRANCHED INTO:
TAP SIZE: 1/2 PRESSURE 60 P.S.I. INCHES W.C. LOCATION 223' N. of center of
W. Second Ave.

PRESSURE TEST: @ 100 psi For 1/4 Hrs. By S. Huffstader
MAIN-SIZE 2" C.I. BARE STEEL COATED STEEL PLASTIC ✓ YEAR INSTALLED 1991
DEPTH: 3 Ft. 0 In. LOCATION 17' W. of center of S. King ST

"A" P/S READING P TOTAL ANODES 1* 0 17* 0 L.R. # 494818

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY