

LOCATION 211 KING GEORGE LN CITY GASTONIA  
BETWEEN KING JAMES LN STREET & KING ARTHUR STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>62'</u>	<u>6-26-98</u>		
MAIN TO PROP. LINE	<u>3/4</u>	<u>Plastic</u>	<u>5'</u>			
PROP. LINE TO BLDG.	<u>3/4</u>	<u>Plastic</u>	<u>57'</u>			

ENTERS: 211 BRANCHED INTO: 0  
TAP SIZE: 3/8 PRESSURE 60 PSI \_\_\_\_\_ INCHES W.C. LOCATION SIDE OF COF KING JAMES LN


PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY RL

MAIN-SIZE 2" C.I. \_\_\_\_\_ BARE STEEL \_\_\_\_\_ COATED STEEL ☒ PLASTIC \_\_\_\_\_ YEAR INSTALLED 1977

DEPTH: 3 FT. 0 IN. LOCATION 17'S OF COF KING GEORGE LN

"A" P/S READING .4 TOTAL ANODES 1# \_\_\_\_\_ 17# 1 L.R. # 465631

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>S</u>	<u>Riser</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	<u>Plastic</u>

ENG. DEPT. USE ONLY