

LOCATION 221 King George CITY Castonia
BETWEEN King James STREET & King Arthur STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>4W</u>	<u>7'</u>	<u>Relocated</u>	<u>2-25-86</u>	
MAIN TO PROP. LINE						
PROP. LINE TO BLDG.						


ENTERS: 221 BRANCHED INTO: 0
TAP SIZE: 3/4 Ser PRESSURE 60 PSI _____ INCHES W.C. LOCATION _____

PRESSURE TEST: @ 100 PSI FOR 1/4 HRS. BY EP
MAIN-SIZE 3/4 C.I. _____ BARE STEEL _____ COATED STEEL ✓ PLASTIC _____ YEAR INSTALLED _____

DEPTH: 2 FT. 6 IN. LOCATION _____

"A" P/S READING 1.3 TOTAL ANODES 1# 0 17# 0 L.R. # _____

REMARKS: _____



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Riser</u>	<u>1.3</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY