

LOCATION 2564 Kings mtn Hwy. CITY Greenville
BETWEEN TRAKAS Blvd STREET & Myrtle School Rd STREET

	SIZE	TYPE	LENGTH	INSTALLED	RETIRED	RENEWED
MAIN TO BLDG.	<u>3/4</u>	<u>PLASTIC</u>	<u>367'</u>		<input checked="" type="checkbox"/>	<u>1-26-1997</u>
MAIN TO PROP. LINE	<u>"</u>	<u>"</u>	<u>36'</u>			
PROP. LINE TO BLDG.	<u>"</u>	<u>"</u>	<u>331</u>			

ENTERS: 2564 BRANCHED INTO: —

TAP SIZE: 3/8 PRESSURE 60 PSI — INCHES W.C. LOCATION


PRESSURE TEST: @ 100 PSI FOR 1 1/4 HRS. BY S. Elmore

MAIN-SIZE 6" C.I. — BARE STEEL — COATED STEEL ☒ PLASTIC — YEAR INSTALLED 1966

DEPTH: 3 FT. 0 IN. LOCATION

"A" P/S READING .7 TOTAL ANODES 1# — 17# — L.R. # —

REMARKS:



Test Station		
Reading & Location	Lead	Volts
P/S Pipeline Lead - Red New Service	<u>Red</u>	<u>Plastic</u>
P/S Pipeline Lead - White Existing Main	<u>E</u>	

ENG. DEPT. USE ONLY